



广微测
Gmicro Testing

MA
2015191236Q



中国认可
国际互认
检测
TESTING
CNAS L1747

GUANGDONG DETECTION CENTER OF MICROBIOLOGY

REPORT FOR ANALYSIS

Report №. 2018FM00168R01

Name of Sample KJ-LD-350 Super Purifier

Applicant

Test Type



Address: Building 59, No.100 Central Xian Lie Road, Guangzhou, China
510070

Postcode:

(020)87137666

Tel:

(020)87137668

Fax:

www.gddcm.com

Website:



广微测
Gmicro Testing



中国认可
国际互认
检测
TESTING
CNAS L1747

GUANGDONG DETECTION CENTER OF MICROBIOLOGY

REPORT FOR ANALYSIS

(Report №.) 2018FM00168R01

Name of Sample	KJ-LD-350	Test Type	Entrusted Inspection
Applicant		Address	
Sample Source		Sample Quantity	
Spec and Lot № of Sample	720*430*127mm、2018001	State and Characteristic	Silver Machine
Sample Received Date	2018-11-06	Completion Date	2018-11-13
Test Standard and Method	GB 21551.3-2010 A		
Item Tested	Antimicrobial Property		
Test Conclusion	<p>The measured data of the tested item of this sample are shown in the following page of test report</p>		
Remarks	<p>Manufacture factory:Guangdong Snorder Environmental Protection Technology Co., Ltd.</p>		



Issue Date

Official Seal

Editor

陈颖婷

Verifier

林保

Approver

李峰

GUANGDONG DETECTION CENTER OF MICROBIOLOGY

ANALYSIS AND TEST RESULT

(Report No.): 2018FM00168R01

Amount of bacteria in the air

			(cfu/m ³)	(%)
(Staphylococcus albus) 8032	0h(CK)	1	5.9×10 ⁴	Sterilization rate
		2	5.9×10 ⁴	
		3	5.9×10 ⁴	
	2h	1	78	99.68
		2	92	99.62
		3	78	99.68
	Average Value			

1.Method: In 30 m³ lab space , use the KJ-LD-350 super purifier to work after 2 hours, samples were sampled with the sieve hole impingement type 6 air microorganism colorator at a suction volume of 28.3 l/min.

2.The results of the sterilization rate test have cleared the influence of the natural extinction factors of organisms in the air

物分
★
检测专用



广微测
Gmicro Testing

MA
2015191236Q



中国认可
国际互认
检测
TESTING
CNAS L1747

GUANGDONG DETECTION CENTER OF MICROBIOLOGY

REPORT FOR ANALYSIS

(Report №.): 2018 FM00168R01

Picture



KJ-LD-350 super purifier



广微测
Gmicro Testing



中国认可
国际互认
检测
TESTING
CNAS L1747

(Report №.): 2018FM00168R01

Notice Items

1.
The Test report is invalid if not affixed with Authorized Stamp of Test and Paging Seal.
2.
The Test report is invalid without signature of verifier and approver.
3.
The Test report is invalid if being supplemented, deleted or altered.
4.
Without prior written permission, the report cannot be reproduced, except in full.
5.
Unless otherwise stated, the results shown in this test report refer only to the sample(s) submitted.
6.
Any dispute of the report must be raised to the testing body within 15 days after the report is received, exceeding which the dispute will not be accepted.
7.
For the tested sample(s) submitted by the applicant, the sample information in the test report is provided by the applicant and the laboratory is not responsible for its authenticity.

