



Station Yard Industrial Estate, Hatton, Derbyshire, DE65 5DU, UK  
Tel.: +44 (0)1283 520365

# Test Report

## ISO 16890:2016-3



Job Number 22945  
Date of Report 16-Mar-22

### Filter Description



PTL Sample ID
36647
NA

Manufacturer	<u>Not specified</u>
Filter Model	<u>Not specified</u>
Part Number	<u>Not specified</u>
Filter Type	<u>Flat sheet media</u>
Dimensions (hxwxh), mm	<u>550 x 415</u>
Effective Filter Area, m <sup>2</sup>	<u>0.17</u>
Media Type	<u>Synthetic</u>
Media Colour	<u>White</u>
Media Additives	<u>Not specified</u>
Electrostatic Charge	<u>Not specified</u>
Sample Obtained	<u>Direct from client</u>

### Test Requester Information

Test Requester	<u>Julian Martin</u>
Date Requested	<u>14/03/2022</u>
Company Name	<u>Martin Industries Ltd</u>
Company Address	<u>Unit 8 Milton Business Centre, Wick Drive, New Milton, BH25 6RH</u>
Date Sample(s) Received	<u>09/03/2022</u>
Date of Test Commencement	<u>14/03/2022</u>

### Test Equipment Information

Optical Particle Counter	<u>Palas, Welas 3000H with 2300 Sensor (only used for fractional efficiency measurements)</u>
Air Flow Meter	<u>Orifice plate with Foxboro Multivariable Transmitter and RTD</u>

### Statement

The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filter performance in all "real life" environments.

### Test Conditions

Dust Type	<u>ISO 12103-1:2016 A2 Fine</u>		
Liquid Aerosol	<u>NA</u>		
Solid Aerosol	<u>NA</u>		
Test Air Flow Rate (nominal), m <sup>3</sup> /hr	<u>918</u>		
Barometric Pressure, mbar	<u>1014.4</u>	<u>1016.7</u>	MIN-MAX
Test Air Temperature, °C	<u>18.6</u>	<u>19.5</u>	MIN-MAX
Relative Humidity, %	<u>36.4</u>	<u>39.4</u>	MIN-MAX

### Manufacturer's Data

Initial Resistance to Airflow, Pa	<u>Not specified</u>
Rated Final Resistance, Pa	<u>Not specified</u>
Initial Efficiency, %	<u>Not specified</u>


### Test Remarks

Filter tested in new condition, as per ISO 16890 part 3.  
Filter had not been previously tested as per ISO 16890 parts 2 and 4 for initial and discharged efficiency.


Test Performed By L. Grimes

## Test Data


Initial Resistance to Airflow (Clean Filter, ISO 16890 part 2)



Resistance to Airflow (Loaded Filter, ISO 16890 part 3)



Arrestance (Loaded Filter, ISO 16890 part 3)



Initial Resistance to Airflow Table  
(Clean Filter, ISO 16890 part 2)

Air Flow, m <sup>3</sup> /hr	Pressure Drop, Pa
459	19
690	35
922	52
1148	73

Loading Dust Fed, Pressure Drop & Arrestance Table  
(Loaded Filter, ISO 16890 part 3)

Dust Fed, g	Pressure Drop, Pa	Arrestance, %
11	67	71
28	97	95
45	142	96
53	168	93
65	204	93

Initial Arrestance, %	71
Average Arrestance, %	91
Test Dust Capacity, g	54

Report Issue	History	Approval	Date
1	First issue to customer	Dr Mike Stillwell CEng	16/03/2022

Particle Technology is accredited in accordance with the recognised International Standard ISO/IEC 17025:2017. This report relates only to the actual item/items tested. Our UKAS Accreditation does not cover opinions and interpretations and any expressed are outside the scope of our UKAS Accreditation. Results of tests not covered by our UKAS Accreditation Schedule are marked NUA (Not UKAS Accredited). This test report must not be reproduced, except in its entirety, without the written permission of Particle Technology Ltd.

© Particle Technology Ltd